DEC INTERNATIONAL TECHNICAL SPECIFICATIONS







STRETCHDEC RECTANGULAR is a superb flexible duct constructed of one layer of corrugated aluminium. By the inter lockseam a high airtightness and flexibility is reached.

APPLICATION

- Suitable for mechanical air supply systems and air conditioning systems.
- Systems, where vapors should be exhausted
- Above mentioned systems, where a special mechanical strength is required

SPECIFICATIONS

DXGR{**X**/L} Article code: -30°C to 250°C Temperature range:

Peak 400°C

up to +3000 Pa Operating pressure: Operating air velocity: max. 30 m/s

Standard length: 0.5, 1 and 3 mtr

CONSTRUCTION

Total layers: 1 of 95micron

CLASSIFICATIONS

EU (EN 13501-1): Α1 UK (BS476): Part 20 FR (NF): M0 DE (DIN4102) Α1


Standards Fulfilling:

REACH Yes **ROHs** Yes

ARTICLE CODE AND DIMENSIONS

DXGR140X54/L - 140X54 DXGR180X54/L - 180X54 DXGR195X54/L - 195X54

HOW TO INSTALL





The information contained in this brochure was current on the The information contained in this brochure was current on the publication date. DEC INTERNATIONAL reserves the right to make changes in details at any time without prior notice. In order to avoid misunderstandings, any interested party is advised to contact DEC INTERNATIONAL checking for any changes in materials and/or information after this brochure was published.

PLEASE NOTICE:

The consultant is responsible for the actual installation and Ine consultant is responsible for the actual installation and mounting of the product. The mentioned values with respect to temperatures are not appropriate to be used to determine the physical properties. These properties are also dependent on humidity and the temperature of the air inside and outside of the H.V.A.C. system.

TRADEMARKS: STRETCHDEC, The DEC logo and DEC International are trademarks, or registered trademarks of Dutch Environment Corporation BV in the Netherlands and/or other countries countries

RESTRICTIONS:

The STRETCHDEC ducts are not suitable for discharging combustion products from open fireplaces and oil-fired boilers. Neither are the ducts suitable for transporting air with a high concentration of acid and base.